



US007196434B2

(12) **United States Patent**
Zhou et al.

(10) **Patent No.:** **US 7,196,434 B2**
(45) **Date of Patent:** ***Mar. 27, 2007**

(54) **MODULAR CONTACTOR ASSEMBLY
HAVING INDEPENDENTLY
CONTROLLABLE CONTRACTORS**

(75) Inventors: **Xin Zhou**, Brookfield, WI (US);
Michael T. Little, Milwaukee, WI
(US); **James Kinsella**, Pleasant View,
TN (US); **Christopher J. Wieloch**,
Brookfield, WI (US)

(73) Assignee: **Eaton Corporation**, Cleveland, OH
(US)

(*) Notice: Subject to any disclaimer, the term of this
patent is extended or adjusted under 35
U.S.C. 154(b) by 432 days.

This patent is subject to a terminal dis-
claimer.

(21) Appl. No.: **10/249,206**

(22) Filed: **Mar. 21, 2003**

(65) **Prior Publication Data**

US 2006/0274459 A1 Dec. 7, 2006

(51) **Int. Cl.**

H02H 3/08 (2006.01)
H01H 83/06 (2006.01)
H01H 77/00 (2006.01)

(52) **U.S. Cl.** **307/131; 335/7; 335/19**

(58) **Field of Classification Search** **335/7,**
335/19, 131; 307/131

See application file for complete search history.

(56) **References Cited**

U.S. PATENT DOCUMENTS

3,292,047 A	12/1966	Lee	317/11
3,310,640 A	3/1967	Bielbtreu	200/1
3,566,152 A	2/1971	Casey et al.	307/133
3,934,110 A	1/1976	Denis	219/131 F
3,982,137 A	9/1976	Penrod	307/136
4,019,017 A	4/1977	Sitek et al.	219/135

4,056,836 A	11/1977	Knauer	361/4
4,128,749 A	12/1978	Spaderna	200/254
4,234,901 A *	11/1980	Strickland, Jr.	361/64
4,354,215 A	10/1982	van der Scheer	361/63
4,398,097 A	8/1983	Schell et al.	307/64
4,445,018 A	4/1984	Holmgren	200/148 A
4,491,708 A	1/1985	O'Leary et al.	200/149 R
4,525,762 A	6/1985	Norris	361/13
4,642,481 A	2/1987	Bielinski et al.	307/252
4,864,157 A	9/1989	Dickey	307/135
4,959,746 A	9/1990	Hongel	361/13
5,172,291 A	12/1992	Bakely et al.	361/85
5,440,180 A	8/1995	DeVault et al.	307/138
5,493,091 A	2/1996	Devautour et al.	218/30

(Continued)

FOREIGN PATENT DOCUMENTS


FR 2 737 040 A 1/1997

Primary Examiner—Stephen W. Jackson
Assistant Examiner—Hal I. Kaplan
(74) *Attorney, Agent, or Firm*—Ziolkowski Patent Solutions
Group, SC

(57) **ABSTRACT**

The present invention provides an electrical isolation apparatus having independently controllable contactors. The isolation apparatus includes a contactor for each phase or pole of an electrical device as well as each phase or pole of a load. Each contactor is constructed so that each includes multiple contact assemblies that may be independently controlled to open and close. Moreover, the contactors within a single contactor assembly or housing can be independently controlled so that the contacts of one contactor can be opened without opening the contacts of the other contactors in the contactor assembly. Additionally, the contactors are constructed and controlled such that a single line side contactor and a single load contactor open simultaneously when an open circuit condition is desired.

22 Claims, 10 Drawing Sheets



US 7,196,434 B2

Page 2

U.S. PATENT DOCUMENTS

5,514,844	A	5/1996	Hamano et al.	218/57	6,377,143	B1	4/2002	Zhou et al.	335/132
5,644,463	A	7/1997	El-Sharkawi et al.	361/94	6,600,238	B1 *	7/2003	Emberty et al.	307/85
5,771,145	A	6/1998	Seymour et al.	361/93	6,797,900	B2 *	9/2004	Hoffinan	200/61.62
5,959,517	A	9/1999	Wieloch et al.	335/16	6,809,911	B2 *	10/2004	Dickhoff et al.	361/23
6,087,800	A	7/2000	Becker et al.	318/778	6,837,729	B2 *	1/2005	Hogue et al.	439/289
6,108,179	A *	8/2000	Katae et al.	361/31	6,967,549	B2 *	11/2005	Zhou et al.	361/160

* cited by examiner




FIG. 1




FIG. 2




FIG. 3




FIG. 4




FIG. 5





FIG. 6

FIG. 7






FIG. 8







FIG. 9



236

FIG. 12



1

**MODULAR CONTACTOR ASSEMBLY
HAVING INDEPENDENTLY
CONTROLLABLE CONTRACTORS**

BACKGROUND OF INVENTION

The present invention relates generally to an electrical switching device, and more particularly, to a modular contactor assembly having independently controllable contactors to protect a poly-phase electrical device, such as a three-phase motor, from current overload. The modular contactor assembly is particularly applicable with high ampacity environments typically associated with large frame contactors and heating load contactors.

Typically, contactors are used in starter applications to switch on/off a load as well as to protect a load, such as a motor, or other electrical devices from current overloading. As such, a typical contactor will have three contact assemblies; a contact assembly for each phase or pole of a three-phase electrical device. Each contact assembly typically includes a pair of stationary contacts and a moveable contact. One stationary contact will be a line side contact and the other stationary contact will be a load side contact. The moveable contact is controlled by an actuating assembly comprising an armature and magnet assembly which is energized by a coil to move the moveable contact to form a bridge between the stationary contacts. When the moveable contact is engaged with both stationary contacts, current is allowed to travel from the power source or line to the load or electrical device. When the moveable contact is separated from the stationary contacts, an open circuit is created and the line and load are electrically isolated from one another.

Generally, a single coil is used to operate a common carrier for all three contact assemblies. As a result, the contactor is constructed such that whenever a fault condition or switch open command is received in any one pole or phase of the three-phase input, all the contact assemblies of the contactor are opened in unison. Simply, the contact assemblies are controlled as a group as opposed to being independently controlled.

This contactor construction has some drawbacks, particularly in high power applications. Since there is a contact assembly for each phase of the three-phase input, the contact elements of the contact assembly must be able to withstand high current conditions or risk being welded together under fault (high current) or abnormal switching conditions. The contact must therefore be fabricated from composite materials that resist welding. These composite materials can be expensive and contribute to increased manufacturing costs of the contactor. Other contactors have been designed with complex biasing mechanisms to regulate "blow open" of the contacts under variable fault conditions, but the biasing mechanisms also add to the complexity and cost of the contactor. Alternately, to improve contact element resistance to welding without implementation of more costly composites can require larger contact elements. Larger contacts provide greater heat sinking and current carrying capacity. Increasing the size of the contact elements, however, requires larger actuating mechanisms, coils, biasing springs, and the like, which all lead to increased product size and increased manufacturing costs.

Additionally, a contactor wherein all the contact assemblies open in unison can result in contact erosion as a result of arcs forming between the contacts during breaking. When all the contact assemblies or sets of contacts are controlled in unison, a detected abnormal condition, such as a fault condition, in any phase of the three-phase input causes all

2

the contact assemblies to break open because the contact assemblies share a bridge or crossbar. Therefore, breaking open of the contacts of one contact assembly causes the contacts of the other contact assemblies to also open. As a result, the contacts may open at non-ideal current conditions. For example, the contactor may be controlled such that a fault condition is detected in the first phase of the three phase input and the contacts of the corresponding assembly are controlled to open when the current in the first phase is at a zero crossing. Since the second and third phases of a three phase input lag the first phase by 120 and 240 degrees, respectively, breaking open of the contacts for the contact assemblies for the second and third phases at the opening of the contacts of the contact assembly of the first phase causes the second and third contact assemblies to open when the current through the contacts is not zero. This non-zero opening can cause arcing between the contact elements of the second and third contact assemblies causing contact erosion that can lead to premature failure of the contactor. This holds true for both abnormal switching as stated above as well as normal duty.

It would therefore be desirable to design a modular electromagnetic contactor assembly having multiple contactors that can be independently controlled such that contact erosion is minimized. It would be further desirable to design such a modular contactor assembly wherein each contactor is constructed in such a manner as to withstand higher currents under fault conditions without increased contactor complexity and size.

BRIEF DESCRIPTION OF INVENTION

The present invention provides a method and apparatus of independently controlling contactors of a modular contactor assembly overcoming the aforementioned drawbacks. The contactor assembly includes a contactor for each phase or pole of an electrical device. The contactor assembly is applicable as both a switching device and an isolation or load protection device. As such, each contactor is constructed so that each includes multiple contact assemblies. Moreover, the contactors within a single contactor assembly or housing can be independently controlled so that the contacts of one contactor can be opened without opening the contacts of the other contactors in the contactor assembly. Additionally, the modular contactor assembly is arranged such that a pair of contactors is serially arranged as a "designated" first pole contactor structure that is arranged in parallel with other pole contactors. With this construction, the contactors of the designated first pole structure are designed to withstand the greatest transient recovery voltage present in the system when the contactors are opened. This reduces the switching stress on the remaining contactors of the assembly.

Accordingly, in one aspect, the present invention includes an apparatus for switching a poly-phase electrical device or protecting a poly-phase electrical device from overload currents. The apparatus includes at least one first pole contactor, at least one second pole contactor, and at least one third pole contactor. Each contactor has multiple contact assemblies that are associated with a single phase of a poly-phase input such that each contact assembly of a contactor is directly connected to a common phase of the poly-phase input. A controller is provided to independently control the at least one first pole contactor, the at least one second pole contactor, and the at least one third pole contactor.

In accordance with another aspect, the present invention includes a contactor assembly having at least four sets of contacts connectable to a three-phase power source. Two of the sets of contacts are in series with one another and in parallel with two other sets of contacts. A controller is connected to open the two sets of contacts connected in series before the other sets of contacts connected in parallel.

According to another aspect of the present invention, an electrical switching apparatus includes a number of contactors housed within a single contactor assembly housing. One of the contactors is a designated first pole contactor and is configured to regulate a single phase of current supplied to a poly-phase load from a poly-phase source. The apparatus further includes a controller configured to control the number of contactors such that the first pole contactor is caused to open first independently of the other contactors.

Various other features, objects and advantages of the present invention will be made apparent from the following detailed description and the drawings.

BRIEF DESCRIPTION OF DRAWINGS

The drawings illustrate one preferred embodiment presently contemplated for carrying out the invention.

In the drawings:

FIG. 1 is a perspective view of a modular contactor assembly in accordance with the present invention.

FIG. 2 is a cross-sectional view of one contactor of the modular contactor assembly taken along line 2—2 of FIG. 1.

FIG. 3 is a cross-sectional view of one contactor of the modular contactor assembly taken along line 3—3 of FIG. 1.

FIG. 4 is a schematic representation of a pair of modular contactor assemblies in accordance with the present invention connected to a soft starter.

FIG. 5 is a schematic representation of a modular contactor assembly in accordance with another aspect of the present invention.

FIG. 6 is a schematic representation of a modular contactor assembly in accordance with the present invention connected to a motor controller.

FIG. 7 is a flow chart setting forth the steps of a technique of independently controlling contactors of a modular contactor assembly in accordance with one aspect of the present invention.

FIG. 8 is a flow chart setting forth the steps of a technique of independently controlling contactors of a modular contactor assembly according to another aspect of the present invention.

FIG. 9 is a flow chart setting forth the steps of a technique for independently controlling contactors of a modular contactor assembly in accordance with another aspect of the present invention.

FIG. 10 is a waveform for a single phase of current during opening a contactor in accordance with the present invention.

FIG. 11 is a waveform for a single phase of current during closing of a contactor in accordance with the present invention.

FIG. 12 is a flow chart setting forth the steps of a technique for independently controlling the making of contactors of a modular contactor assembly in accordance with a further embodiment of the invention.

DETAILED DESCRIPTION

The present invention will be described with respect to an electromagnetic contactor assembly for use in starter applications, such as the switching on off of a load, as well as to protect a load, such as a motor, from current overload. The electromagnetic contactor assembly and controls of the present invention are equivalently applicable to heating load ecator assembly, on-demand modular contactor assemblies, modular large frame contactor assemblies, and the like. The present invention is also applicable with other types of contactor assemblies where it is desirable to reduce contact erosion resulting from arcs during breaking and bounce arcs during making of the contacts. Additionally, the present invention will be described with respect to implementation with a three-phase electrical device; however, the present invention is equivalently applicable with other electrical devices.

Referring now to FIG. 1, a modular contactor assembly 10 is shown in perspective view. The modular contactor assembly 10 includes electromagnetic contactors 12A–C for a three phase electrical system. Each contactor 12A–C is designed to switch current to a motor or other electrical device. In the shown configuration, contactors 12A–C are mounted to plate 11 configured to support each of the contactors as well as an optional cover (not shown). In the illustrated embodiment, each of the contactors 12A–C of contactor assembly 10 is connected to facilitate connection to an overload relay 13A–C for use in a starter that operates in industrial control applications, such as motor control. Assembly 10 could equivalently be implemented without relays 13A–C for other applications. Apertures 14A–C located in each relay 13A–C, respectively, facilitate electrical connection of lead wires to the contactor assembly. Since each contactor/overload relay includes three apertures; a common bus plate (not shown) jumping all three apertures could be inserted for the end user to attach single point wiring. The bus plate may include lugs or ring terminals for the end user to connect wires to the assembly. As will be described in greater detail below, this three-way connection for each phase is beneficial under fault conditions as the current for each phase A–C can be distributed evenly within each contactor to assist with minimizing contact arcing and contact erosion, especially on make. Each contactor 12A–C includes a top cover 16A–C that is secured to the contactor frame via screws 18A–C. Each relay 13A–C also includes a cover 20A–C that is snapped to the relay frame and is hinged to allow access to an FLA adjustment potentiometer (not shown). Each relay 13A–C includes a reset button 22A–C.

Referring to FIG. 2, a longitudinal cross-sectional view of one of the contactors 12A–C of the modular contactor assembly 10 taken along line 2—2 of FIG. 1 is shown (without overload relay 13A–C from FIG. 1). Specifically, contactor 12A is cross-sectionally shown but a cross-sectional view of contactors 12B or 12C would be similar. Contactor 12A is shown in a normally open operating position prior to energization of an electromagnetic coil 24 with contacts 26, 28 separated and open. Coil 24 is secured by the contactor housing 30 and is designed to receive an energy source or an in-rush pulse at or above an activation power threshold that draws armature 32 into the magnet assembly 35. A movable contact carrier, secured to the armature 32, is also drawn towards magnet assembly 35. Contacts 28, which are biased by spring 34 towards stationary contacts 26, are now positioned to close upon stationary contacts 26 and provide a current path. After energization of coil 24, a second energy source at or above a reduced

holding power threshold of the coil **24** is provided to the coil and maintains the position of the armature **32** to the magnet assembly **35** until removed or a high fault current occurs thereby overcoming the reduced power threshold to disengage the armature from the magnet assembly causing the separation of the contacts, as will be described in greater detail hereinafter.

Magnet assembly **35** consists of a magnet post **36** firmly secured to magnet frame **86**. Magnet post **36**, magnet frame **86**, and armature **32** are typically solid iron members. Coil **24** includes a molded plastic bobbin wound with copper magnet wire and is positioned centrally over magnet post **36** and inside magnet frame **86**. Preferably, coil **24** is driven by direct current and is controlled by pulse width modulation to limit current and reduce heat generation in the coil. When energized, magnet assembly **35** attracts armature **32** that is connected to a movable contact carrier **39**. Moveable contact carrier **39** along with armature **32** is guided towards magnet assembly **35** with guide pin **40** and molded housing **30** walls **46**, **48**.

Guide pin **40** is press-fit or attached securely into armature **32** which is attached to movable contact carrier **39**. Guide pin **40** is slidable along guide surface **42** within magnet assembly **35**. The single guide pin **40** is centrally disposed and is utilized in providing a smooth and even path for the armature **32** and movable contact carrier **39** as it travels to and from the magnet assembly **35**. Movable contact carrier **39** is guided at its upper end **44** by the inner walls **46**, **48** on the contactor housing **30**. Guide pin **40** is partially enclosed by an armature biasing mechanism or a resilient armature return spring **50**, which is compressed as the movable contact carrier **39** moves toward the magnet assembly **35**. Armature return spring **50** is positioned between the magnet post **36** and the armature **32** to bias the movable contact carrier **39** and armature **32** away from magnet assembly **35**. A pair of contact bridge stops **52** limits the movement of the contact bridge **54** towards the arc shields **56** during a high fault current event. The combination of the guide pin **40** and the armature return spring **50** promotes even downward motion of the movable contact carrier **39** and assists in preventing tilting or window-locking that may occur during contact closure. When the moveable contact carrier **39**, along with armature **32**, is attracted towards the energized magnet assembly **35**, the armature **32** exerts a compressive force against resilient armature return spring **50**. Together with guide pin **40**, the moveable contact carrier **39** and the armature **32** travel along guide surface **42** in order to provide a substantially even travel path for the moveable contact carrier **39**. Three pairs of crimping lugs **58** are provided per contactor and used to secure lead wires to the contactor. Alternatively, a common busbar containing stationary contacts (not shown) may be used as a base for end user wire connection either through ring terminals or appropriately sized lug.

Referring to FIG. 3, a lateral cross-sectional view of the contactor **12A** is depicted in the normal open operating position prior to energization of the electromagnetic coil **24**. Initially, the armature **32** is biased by the resilient armature return spring **50** away from the magnet assembly **35** toward the housing stops **60** resulting in a separation between the armature and core. The contact carrier assembly also travels away from the magnet assembly **35** due to the armature biasing mechanism **50** which creates a separation between the movable contacts **28** and the stationary contacts **26** preventing the flow of electric current through the contacts **26**, **28**. Biasing springs **34** are connected to a top surface **62**

of movable contact **64** and are extended such that a maximum space **63** results between the top of the spring and the movable contact **64**.

Referring now to FIG. 4, a pair of modular contactor assemblies **66** and **68** is shown as isolation devices connected to a softstarter **70**. Contactor assembly **66** includes, in a three-phase application, three contactors **72A**, **72B**, **72C** that carry power from a line power source **74** via lines A, B, and C, respectively. Similarly, contactor assembly **68** also includes three contactors **76A**, **76B**, **76C** for a three-phase load **78**. As illustrated, there are three contactors within a single contactor assembly before and after the soft starter. Contactor assemblies **66** and **68** are designed to provide galvanic isolation to the soft starter by independently "breaking open" their contactors after the soft starter interrupts the circuit, or in the case of a shorted Silicon Controlled Rectifier (SCR) in the soft starter, interrupt the load themselves (fault condition). Each contactor of contactor assemblies **66**, **68** includes multiple contacts. Preferably, each contactor includes three contact assemblies and each contact assembly includes one line side contact, one load side contact, and one connecting or bridge contact for connecting the line and load side contacts to one another. For example, the bridge contacts may be moveable contacts such as those previously described.

Controller **80** is connected to an actuating assembly (not shown) in each contactor that is arranged to move the contact assemblies of each contactor in unison between an open and closed position. Each actuating assembly comprises a coil, armature, and magnetic components to effectuate "breaking" and "making" of the contacts, as was described above. Controller **80** is designed to transmit control signals to the actuating assemblies to independently regulate the operation of the contactors. The controller triggers the actuating assemblies based on current data received from a current sensing unit **82**, that in the embodiment shown in FIG. 4, is constructed to acquire current data from first phase or pole A of the three-phase line input. While current sensing unit **82** is shown to acquire current data from first phase or pole A, current sensing unit **82** could be associated with the second or third phases or poles B and C of the three-phase line input.

Since each contactor **72A-C** and **76A-C** has its own actuating assembly, each contactor may be independently opened and closed. This independence allows for one contactor to be opened without opening the remaining contactors of the modular contactor assembly. For example, a first contactor **72A**, **76A** can be opened and the remaining contactors **72B-C**, **76B-C** can be controlled to not open until the contacts of the first contactor **72A**, **76A** have cleared. This delay and subsequent contactor opening reduces arc erosion of the contacts of the subsequently opened contactors since each contactor can be controlled to open when the phase for that contactor is at or near a zero current point. Thus, arcing time is at a minimum. As described above, each contactor **72A-C**, **76A-C** includes three contact assemblies **84A-C**, **86A-C**. Each contact assembly is made up of movable contacts and stationary contacts. The contact assemblies within each contactor are constructed to open in unison and are therefore controlled by a common crossbar or bridge. As such, the contact assemblies within a single contactor operate in unison, but the contactors are asynchronously or independently operated with respect to another. As will be described below, controller **80** is connected to contactors **72A** and **76A** directly

but is connected to contactors **76B–C** and **76B–C** in parallel. As such, contactors **72B–C** and **76B–C** can be controlled simultaneously.

Referring now to FIG. 5, contactor assembly **88** may be implemented as a switching device to control and protect a load **89** connected thereto. Contactor assembly **88** includes three contactors **90A–C**. The number of contactors coincides with the number of phases of the line input **92** as well as load **89**. Therefore, in the example of FIG. 5, a contactor is provided for each phase of the three-phase line **92** and load **89**. Each contactor **90A–C** includes a corresponding contact assembly **94A–C**. Each assembly **94A–C** includes multiple line side contacts **96A–C** and multiple load side contacts **98A–C**. Each contactor includes an actuating assembly **100A–C** that is connected to and controlled by a controller **102**. Controller **102** controls breaking and making of the contacts of each contactor by triggering the actuating assembly in the contactor based on fault data received from transducers **104A–C**. Alternately, breaking and making of the contacts could be controlled by an override control or switch **106**.

The timing of the breaking of each contactor is determined based on current data received from transducers **104A–C**. In a three-phase input environment, three transducers **104A**, **104B**, and **104C** are used. By implementing a transducer for each phase, each contactor may be identified as the “first” pole contactor, as will be described in greater detail below. Conversely, only one transducer may be implemented to collect current data from one phase and the contactor corresponding to that phase would be considered the “first” pole contactor. However, any contactor can be the “first” pole contactor.

Referring now to FIG. 6, a contactor assembly **108** is shown in a typical motor control application configuration between a power line source **110** and a three-phase motor **112**. Contactor assembly **108** is a modular contactor assembly and includes four contactors **114A, A', B, C** similar to the contactors heretofore described. Each contactor **114A, A', B, C** includes a set of contact assemblies **116A, A', B, C**. Specifically, each contact assembly includes a set of line side contacts **118A, A', B, C** and load side contacts **120A, A', B, C**. Each contactor also includes an actuating assembly **122A, A', B, C** that breaks and makes the contact assemblies of each respective contactor in unison. However, since each contactor has its own actuating assembly, the contactors can be independently controlled.

Connected to each actuating assembly and constructed to independently control the contactors is controller **124**. Controller **124** opens and closes each contactor based on the corresponding phase **A–C** of the contactor crossing a particular current value or voltage value. In one embodiment, each contactor is controlled to open when the current in the corresponding phase is approximately zero. Opening of the contacts of the contactor at or near a zero current reduces the likelihood of arc erosion between the contacts of the contactor. However, controller **124** can be configured to independently open the contactors based on the current in the corresponding phase reaching/crossing a particular non-zero value. Current data is acquired by at least one current sensor (not shown) connected between the line **110** and the contactors **114A–C**.

Still referring to FIG. 6, contactors **114A** and **114A'** are shown as being serially connected to another. This configuration has a number of advantages, particularly for high voltage applications (i.e. greater than 600 V). Connecting two contactors in series and designating the two contactors as the first contactors to open when a fault is detected or

open command is issued allows the two serially connected contactors **114A, A'** to share high switching energy stress. As a result, more energy is dissipated in the contactors **114A, A'** thereby reducing the energy absorption burden of contactors **114B, C**. Additionally, since contactors **114A, A'** are also connected to the controller in parallel with another, the controller can cause contactors **114A, A'** to open simultaneously. This results in a greater arc voltage being generated by the four arcs as opposed to a conventional double break system and reduces the current and contact erosion. The multiple contact gaps also reduce the likelihood of reignitions after current zero.

The configuration illustrated in FIG. 6 shows an embodiment of the present invention; however, additional configurations not shown are contemplated and within the scope of this invention. For example, in jogging applications, three sets of two serially connected contactors may be arranged in parallel and independently controlled.

As stated above, the modular contactor assembly includes multiple contactors that are independently opened by an actuating mechanism controlled by a controller based on current data acquired from one or more current sensors. Since the contactors have a unique actuating assembly, the contactors can be controlled in accordance with a number of control techniques or algorithms. Some of these control schemes will be described with respect to FIGS. 7–9.

Referring now to FIG. 7, the steps of a control technique or algorithm for a modular contactor assembly in accordance with the present invention is shown. The steps carried out in accordance with technique **126** are equivalently applicable with a modular isolation contactor, a modular heating load contactor, a modular on-demand switching contactor, and the like. The steps begin at **128** with identification that an open condition is desired **130**. Identification of a desired open condition may be the result of either a dedicated switch open command or a fault indicator signal indicating that a fault condition is present and at least one contactor should be opened. If an open condition is not desired **130, 132**, the technique recycles until an open condition is desired **134**. When an open condition is desired **130, 134**, current in a phase of the input power is monitored at **136** using a current sensor. Current is monitored to determine when a specified current condition **138** occurs. Until the current condition occurs **138, 140**, current in the phase is monitored. Once the current condition occurs **138, 142**, a wait step **144** is undertaken.

The current condition, in one embodiment, is a current zero in the monitored phase of the three-phase input. Wait step **144** is a time delay and is based on the time required from the actuating assembly receiving the switch open signal to the actual contact separation of the corresponding contactor. After the time delay has expired **144**, a switch or break open signal is sent to the actuating assembly for a single contactor at step **146**. The multiple contact assemblies for the contactor are then caused to open and, as such, an open circuit is created between the line and load for the corresponding phase of the three-phase input.

After the single contactor is opened at step **146**, a wait step **148** is once again undertaken. The waiting period at step **148** is of sufficient length to insure that the single contactor has opened before the remaining contactors of the contactor assembly are opened at **150**. Preferably, the contacts of the single contactor are opened one to two milliseconds before current zero. After the remaining contactors are opened at step **150**, all of the contactors are opened and an open circuit between the line and load is created **152**.

Referring now to FIG. 8, another technique 154 for controlling modular contactors in a single contactor assembly begins at step 156, and awaits a desired open switching or fault command at step 158. If an open condition is not desired 158,160, technique 154 recycles until an open condition is desired 158,162. When an open condition is desired, current in each phase of the three-phase input signal is monitored at 164. As such, technique 154 is particularly applicable with a modular contactor assembly dedicated for controlled switching wherein each phase has a dedicated current sensor or transducer, similar to that described with respect to FIG. 5.

Current is monitored in each phase to determine when a current condition in that phase occurs 166. Monitoring continues until current in the phase crosses a specific point or value 166, 168. The current condition is preferably defined as the next current zero in the phase following receipt of the switching or fault indicator signal. However, the current condition could also be any non-zero point on the current wave. Once the current condition is identified in a single phase 166, 170, technique 154 undergoes a wait or hold step at 172. The time period of the wait step 172 is a delay time based on the time required from an actuating assembly receiving an open contactor signal for that contactor to the actual breaking of the contacts in the contactor. Once the delay time has expired, the contactor for the phase in which the current zero condition was identified is opened at step 174. Preferably, the contact assemblies of the contactor are opened in unison one to two milliseconds before the next current zero in the phase corresponding thereto.

Once the contactor is opened 174, a determination is made as to whether there are additional contactors that are unopened 176. If so 176, 178, technique 154 returns to step 162 wherein current is monitored in the phases of the closed contactors. As such each contactor is independently opened with respect to one another. Because the second and third phase current will have the same phase angle after the first phase is cleared, the contactors in the last two phases will open simultaneously. Once all the contactors are opened 176, 180, the process concludes at step 182 with all of the contactors being in an opened or broken state.

Referring now to FIG. 9, a technique or process 184 particularly applicable to independently controlling contactors of a modular isolation contactor assembly begins at 186, and at step 188 a switching or fault command indicative of a desired open condition is identified. If an open condition is not desired 188, 190, the process recycles until such a command is received. Failure to receive such command is indicative of a desire for continued electrical connection between a line and a load. Once a switching or fault indicator signal or command is received 188, 192, current is monitored using a current sensor in one phase of a three-phase input signal. Any phase of a three-phase input may be monitored but preferably, only one phase is, in fact, monitored. Current in the phase is monitored to determine when a specified current condition occurs 196. Preferably, the current condition is defined as a current zero signal being received from the current sensor based on the monitored phase crossing a current zero point. However, a non-zero point on the current signal could also be considered the specified current condition. If a current condition is not received 196, 198, the process continues monitoring current in the selected phase. Once the current condition occurs and is identified by the controller 196, 200, the process implements a wait step 202 before the controller transmits a break open signal to an actuating assembly for the single contactor corresponding to the monitored phase. The wait or delay

period is based on a time interval required from the actuating assembly receiving the signal to the breaking open of the corresponding contactor.

Once the delay time has expired 202, the contactor corresponding to the monitored phase is opened at 204. Preferably, the contactor is broken at a point one to two milliseconds before the next current zero in the corresponding phase. At step 206, the process waits until the multiple contacts have opened before opening the remaining contactors at step 208. Preferably, the remaining contactors are opened simultaneously. For example, in a three-phase environment, a first pole contactor would be opened and subsequent thereto the contactors for the second and third poles, respectively, would be simultaneously opened by their respective actuating assemblies. Once all the contactors are opened, the line and load are isolated from each other and the process ends 210.

The present invention has been described with respect to independently breaking contactors of a modular contactor assembly. However, there are a number of advantages of the present invention with respect to making or closing of independently controlled contactors. Point-on-Wave (POW) switching or control is particularly advantageous with the modular contactor assembly of the present invention. POW switching allows the contacts of a contactor to be closed based on voltage data acquired from a voltage sensor and be opened based on current data acquired from a current sensor. POW switching reduces contact erosion and therefore improves contact switching by breaking open the contacts of the contactor in such a manner as to minimize or prevent an arc being formed between the contacts. For closing of the contacts, POW switching is also beneficial in reducing negative torque oscillations in the motor (load) by closing the contacts at precise voltage points.

Referring now to FIG. 10, a typical sinusoidal current waveform 212 for a single phase of a three-phase power signal is shown. The value of the current varies along each point of the waveform from a maximum negative current value 214 to a maximum positive current value 216. Between successive minimum values (or maximum values), the waveform crosses a zero point 218. At point 218, the current for the corresponding phase being applied to the load is at or near a minimum. As discussed above, it is desirable to open a contactor when the current waveform is at or near point 218 to reduce an arc being formed between the contacts of the contactor.

Waveform 212 is generally constant as power is supplied to the load. Variations in magnitude, frequency, and phase will occur over time, but waveform 212 is generally constant. According to one aspect of the present invention, when an open condition is desired, a switching command or fault indicator signal 220 is received. In FIG. 10, the switching signal is shown relative to the current waveform and corresponds to when the waveform is at point 214. However, this is for illustrative purposes only and the switching or open signal can be received at any point in the current continuum. If the contacts were opened the moment the open condition was desired (switching signal received), the magnitude of the current at that point would be at or near a maximum. This would increase the break arcing time and subsequent contact erosion. Therefore, the controller delays the opening of the contactor by an interval t_d . At point 222 the contacts of the contactor are opened. An open circuit condition between the line and the load for that phase does not immediately occur. There is a period Δt between the separation of the contacts and an open circuit condition. At Δt , the short duration of break are 224 occurs and helps to minimize contact erosion

and to prevent resumption after current zero, as was discussed above. At point **226** on the waveform, the contactor is opened and an open condition between the line and load is achieved.

Point-on-wave switching is an advantage of the present invention. The purpose of point-on-wave closing is to minimize the asymmetric component in the make currents so to reduce negative torque oscillations in a motor (load) as well as to minimize the bounce arc erosion and contact welding. Referring now to FIG. **11**, a set of voltage and current waveforms **228**, **229**, respectively, for a single phase of a three phase power signal is shown to illustrate "making" or closing of a contactor in accordance with the present invention. The designated 1st pole to close does not need to "make" at any specific phase angle of the system voltage since there will be no current flow through the contactor. The 2nd and 3rd poles, however, close at a specific point on the voltage wave form to reduce negative torque oscillations. Making of the contacts in each of the 2nd and 3rd contactors is based on at least one voltage data value from a voltage sensor, and in the illustrated example, a close contactor signal is received at point **230** on the waveform. A delay period t_d is observed whereupon only after the designated first pole contactor is closed. After the time delay has lapsed, the contacts of a second contactor are closed at point **232** which is preferably within a 65 to 90 degree phase angle of the system voltage depending on the power factor of the load. Arcing due to contact bounce can also be minimized or eliminated by using multiple sets of contacts in each contactor. Reducing bounce arc **234** is advantageous as it also leads to contact erosion and contact welding. Controlling when the contacts are closed also reduces negative torque oscillations in the motor.

The steps of a technique or process of "making" or closing contactors independently of a modular or multi-contactor assembly are set forth in FIG. **12**. The technique **236** begins at **238** with a switching command being sent from the controller to the actuating assembly or assemblies for the designated first pole contactor **238**. As stated above, the designated first pole contactor may be closed independent of the specific phase angle of the system voltage because there is no current flowing through the contactor prior to its closing. Based upon the switching command, the actuating assembly for the designated first pole contactor causes the contacts within the contactor to close at **240**. It should be noted that the present technique **236** may be implemented with a contactor having a single actuating assembly or more than one actuating assembly. Additionally, while it is preferred that each contactor includes multiple sets of contacts, the present technique **236** may be implemented with a contactor having a single set of contacts.

After the designated first pole contactor has closed **240**, a defined phase angle of the system voltage in the phase corresponding to a non-first pole contactor is monitored at **242**. By monitoring the phase in a non-first pole contactor, the non-first pole contactor may be closed at a specified point on the waveform. A signal indicative of the defined phase angle in the system voltage corresponding to the non-first pole contactor is transmitted to the controller at **244**. The defined phase angle signal may be transmitted from a voltage sensor or other detection or sensory device. Upon receipt of the defined phase angle signal, the controller waits until expiration of a delay time at **246**. The delay time, as discussed previously, is based on the amount of time required from the actuating assemblies of a contactor receiving a switching signal to the closing of the contacts in a contactor. Upon expiration of the time delay, the controller

sends a close contact signal to the actuating assemblies of the non-first pole contactor **248** thereby causing the contacts of the non-first pole contactor to close at **250**. As stated above, the non-first pole contactor is preferably closed between approximately 65 degrees to approximately 90 degrees of the phase angle of the system voltage depending upon the power factor of the load.

After the non-first pole contactor is closed at **250**, a determination is made as to whether additional contactors remain open at **252**. If all the contactors have not been closed **252**, **254**, the technique or process returns to step **242** and carries out the steps or functions previously described. However, if all the contactors of the contactor assembly have closed **252**, **256**, technique **236** ends at **258** with current flowing through each of the contactors. Preferably, at the conclusion of technique **236**, the controller implements one of the techniques or processes previously described with respect to FIGS. **7**, **8**, or **9** to independently control the opening of the contactors of the contactor assembly when an open condition is desired.

The present invention has been described with respect to designated first pole switching wherein the contactor for one pole or phase of a three-phase input or load is broken or opened before the remaining contactors are opened. An advantage of this construction is that any contactor may be designated the "first" pole contactor. Further, this designation can be selectively changed such that the "first" pole designation is rotated among all the contactors. Rotating the "first" pole designation between the contactor events out contact erosion between the contactors thereby achieving constant and consistent operation of the contactors. The rotation designation can be done automatically by programming the controller to change designation after a specified number of make-and-break events or manually by changing the order in which the lead wires are connected to the contactor assembly.

Accordingly, in one embodiment, the present invention includes an apparatus for protecting a poly-phase electrical device from current overloading. The apparatus includes at least one first pole contactor, at least one second pole contactor, and at least one third pole contactor. Each contactor has multiple contact assemblies that are associated with a single phase of a poly-phase input such that each contact assembly of a contactor is directly connected to a common phase of the poly-phase input. A controller is provided to independently control the at least one first pole contactor, the at least one second pole contactor, and the at least one third pole contactor.

In accordance with another embodiment, the present invention includes a contactor assembly having at least four sets of contacts connectable to a three-phase power source. Two of the contacts are in series with one another in one phase and in parallel with two other sets of contacts in the other two phases. A controller is connected to open the two sets of contacts connected in series before the other sets of contacts connected in parallel.

According to another embodiment of the present invention, an electrical switching apparatus includes a number of contactors housed within a single contactor housing. One of the contactors is a designated first pole contactor and is configured to regulate a single phase of current supplied to a poly-phase load from a poly-phase source. The apparatus further includes a controller configured to control the number of contactors such that the first pole contactor is caused to open independently of the other contactors.

The present invention has been described in terms of the preferred embodiment, and it is recognized that equivalents,

13

alternatives, and modifications, aside from those expressly stated, are possible and within the scope of the appending claims.

What is claimed is:

1. An apparatus for protecting a poly-phase electrical device from current overloading, the apparatus comprising: at least one first pole contactor, at least one second pole contactor, and at least one third pole contactor;

each contactor comprised of multiple contact assemblies and associated with a single phase of a poly-phase input such that multiple contact assemblies of a contactor are connected directly to a common phase of the poly-phase input;

a controller configured to independently control the at least one first pole contactor, the at least one second pole contactor, and the at least one third pole contactor; and

wherein the controller is further configured to cause the at least one second pole contactor and the at least one third pole contactor to open only after the at least one first pole contactor has cleared.

2. The apparatus of claim 1 wherein the at least one first pole contactor includes a pair of first pole contactors connected in series.

3. The apparatus of claim 2 wherein the controller is further configured to open the pair of first pole contactors substantially simultaneously.

4. The apparatus of claim 3 wherein the controller is further configured to open the pair of first pole contactors without opening another of the at least one second pole contactor and the at least one third pole contactor.

5. The apparatus of claim 1 wherein multiple contact assemblies within a contactor are controlled in unison by a common actuating assembly.

6. The apparatus of claim 1 wherein one of the at least one first pole contactor, the at least one second pole contactor, and the at least one third pole contactor is configured to open without opening another of the at least one first pole contactor, the at least one second pole contactor, and the at least one third pole contactor.

7. The apparatus of claim 1 having only one contactor per pole of the poly-phase electrical device.

8. The apparatus of claim 1 wherein one of the at least one first pole contactor, the at least one second pole contactor, and the at least one third pole contactor is designated to open before another of the at least one first pole contactor, the at least one second pole contactor, and the at least one third pole contactor when an open condition is desired.

9. The apparatus of claim 8 wherein the controller is further configured to rotate which contactor of the at least one first pole contactor, the at least one second pole contactor, and the third pole contactor is designated to open before another contactor.

10. A contactor assembly comprising:

at least four sets of contacts connectable to a three-phase power source, two of which are in series with one another in one phase and in parallel with two other sets of contacts in the other two phases, wherein the at least four sets of contacts include three sets of contacts

14

housed in a single contactor housing and one set of contacts housed in another contactor housing; and a controller connected to open the two sets of contacts connected in series before the other sets of contacts connected in parallel.

11. The contactor assembly of claim 10 wherein the at least four sets of contacts include two sets of contacts for each phase of the poly-phase load.

12. The contactor assembly of claim 11 wherein the two sets of contacts are configured to open substantially simultaneously.

13. The contactor assembly of claim 10 wherein four single contactor housings are mounted in a single contactor assembly housing.

14. The contactor assembly of claim 11 wherein the two sets of contacts correspond to a designated first pole.

15. The contactor assembly of claim 13 wherein the controller is further configured to periodically rotate which sets of contacts correspond to the designated first pole.

16. An electrical switching apparatus comprising: a number of contactors housed within a single contactor assembly housing, one of the contactors designated as a first pole contactor and configured to regulate a single phase of current supplied to a poly-phase load from a poly-phase source;

a controller configured to control the number of contactors such that the first pole contactor is caused to open independently of other contactors; and

wherein the controller is further configured to cause the other contactors to open only after the first pole contactor has cleared.

17. The electrical switching apparatus of claim 16 wherein the controller is further configured to cause the other contactors to open substantially simultaneously.

18. The electrical switching apparatus of claim 16 wherein the controller is further configured to periodically rotate which contactor of the number of contactors is designated as the first pole contactor.

19. The electrical switching apparatus of claim 16 wherein each contactor includes multiple sets of contacts and wherein the multiple sets are configured to open substantially simultaneously.

20. The electrical switching apparatus of claim 19 wherein each contactor includes three sets of contacts and each set of contacts includes a pair of stationary contacts and a movable contact such that engagement of the movable contact with the pair of stationary contacts causes current to pass therebetween.

21. The electrical switching apparatus of claim 20 wherein one stationary contact is a line side contact and the other stationary contact is a load side contact.

22. The electrical switching apparatus of claim 20 wherein the controller is further configured to cause the movable contact to separate from the pair of stationary contacts of a set of contacts within a contactor when current through the movable contact and the pair of stationary contacts is at or near a zero condition.

* * * * *